

Document 00910

**ADDENDUM NO. 3**

Date of Addendum: 2-2-16

**PROJECT NAME: Central Library Plaza - Improvements**

**PROJECT NO: E-000197**

**SUBMITTAL DATE: February 18, 2016**

**FROM:** City of Houston, General Services Department  
900 Bagby, 2<sup>nd</sup> Floor  
Houston, Texas 77002  
Attn: Parker Le, Sr. Project Manager

**TO: Prospective Respondents**

This Addendum forms a part of the Request For Qualifications (RFQ) and it will be incorporated into the Contract, as applicable. Insofar as the original RFQ is inconsistent, this Addendum governs.

The following changes, modifications, corrections, clarifications, additions and/or deletions as set forth herein shall apply to the above referenced proposal package and shall be made apart hereof and be subject to all of the requirements as though originally specified and/or shown. The contractor shall acknowledge receipt of this addendum in the appropriate blank of the bid proposal form.

1. Clarification: All Alternates are Add Alternates. See Proposal Form - Part B. Stipulated price is "Total Proposal Price; Iminus Base Unit Prices, Extra Unit Prices, Contractor Incentive/bonus, Cash Allowances and All Alternates."

2. Powder Coating on Grating at Shade Structure:

Drawing A1.00, Project Information, Note 5 Grating Types, finishes to be as follows:

Type 1 aluminum grating:

Base Bid: Aluminum mill finish

Alternate No. 3: Powder coated, color to be selected

Type 2 aluminum grating:

Base Bid: Field painted

Alternate No. 3: Powder coated, color to be selected

Powder coating: AAMA 2605 specifications, 10 year warranty. Color to be from stock color selection equal to or greater than range available through Quality Powder Coating, Carrollton, Texas (972) 488-0635.

3. Downspout:

At the shade structure column C1/N2, add 4" round pvc downspout inside steel column. Secure top of downspout at the gutter; extend gutter flashing into downspout. Discharge the downspout through above grade side opening in column. Re: 2A1.06, 2A1.07, 4A1.07

4. Project Manual, Section 08 68 00 Point Supported Glazing Systems, para. 1.3.E, Delegated-Design Submittal, add the following:

2. Provide engineered shop drawings for the glass panel roof design. Design details to include all components, connections, material schedule, and the method of anchoring to the structural frame. Drawings to be sealed, signed and dated by a registered Texas Engineer. Submit to City of Houston as a deferred submittal for permit.


5. Project Manual, Section 32 31 00 Steel Fence, Part 1 - General, add the following:

D. Provide engineered shop drawings for all fences and gates. Design details to include all components, connections, material schedule, and the foundations and methods of anchoring to the existing structure. Drawings to be sealed, signed and dated by a registered Texas Engineer. Submit to City of Houston as a deferred submittal for permit.

6. Chamberlin Roofing and Waterproofing can provide additional info. regarding warranty for existing waterproofing. (713) 880-1432.

7. Granite walls and planters shall be Café Imperial. Granite pavers and steps shall be Mountain Green. Available through Cangelosi (281) 499-0561.

END OF ADDENDUM NO. 3

(CRC:   
Humberto Bautista, P.E.  
City Engineer  
General Services Department

2-12-16  
DATE